

Energy performance certificate (EPC)

White Swan 19 Church Street Ockbrook DERBY DE72 3RB	Energy rating C	Valid until: 18 August 2030
		Certificate number: 0550-0830-0692-2308-4006


Property type	A3/A4/A5 Restaurant and Cafes/Drinking Establishments and Hot Food takeaways
Total floor area	253 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

30 B

If typical of the existing stock

88 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	114.55
Primary energy use (kWh/m ² per year)	660

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0080-5264-0490-0530-8020\)](/energy-certificate/0080-5264-0490-0530-8020).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Kieran Wilshaw
Telephone	01924669940
Email	kwilshaw@compliance365.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID207047
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	Compliance365
Employer address	
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	5 August 2020
Date of certificate	19 August 2020
