Energy performance certificate (EPC)

Red Lion High Street STONE ST15 8AJ Energy rating

Valid until: 14 February 2033

Certificate number: 3799-1469-9530-4713-3544

Property type

Restaurants and Cafes/Drinking Establishments/Takeaways

Total floor area


389 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	28 B
If typical of the existing stock	114 E

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	62.97
Primary energy use (kWh/m2 per year)	364
Primary energy use (kWh/m2 per year)	364

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\underline{\text{recommendation report}}$ $\underline{\text{(/energy-certificate/3413-3978-5742-1665-8830)}}$.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name Katharine Davenport

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO035284
Telephone	0330 124 9660
Email	certification@stroma.com
About this assessment	
Employer	Compliance 365
Employer address	6 Mariner Court
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	8 December 2022
Date of certificate	15 February 2023